



# IECEX Certificate of Conformity

## INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification Scheme for Explosive Atmospheres

for rules and details of the IECEx Scheme visit [www.iecex.com](http://www.iecex.com)

Certificate No.: IECEx BAS 12.0118X issue No.:0 Certificate history: \_\_\_\_\_

Status: **Current**

Date of Issue: 2014-01-21 Page 1 of 3

Applicant: **Synatel Instrumentation Limited**  
Walsall Road  
Norton Canes  
Cannock  
Staffordshire  
WS11 9TB  
United Kingdom

Electrical Apparatus: **Type 30mm Range of sensors**  
Optional accessory:

Type of Protection: **Encapsulation**

Marking: **Ex ma IIC T5 Ga**  
**Ex ma IIIC T100°C Da Tamb -15°C to +50°C**

Approved for issue on behalf of the IECEx  
Certification Body:

*P R S Sinclair* *M POWNEY*

Position: General Manager

Signature:  
(for printed version)

*M Powney*  
\_\_\_\_\_  
21/1/14

Date:

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting the [Official IECEx Website](http://www.iecex.com).

Certificate issued by:

**SGS Baseefa Limited**  
Rockhead Business Park  
Staden Lane  
Buxton  
Derbyshire  
SK17 9RZ  
United Kingdom





# IECEx Certificate of Conformity

Certificate No.: IECEx BAS 12.0118X

Date of Issue: 2014-01-21

Issue No.: 0

Page 2 of 3

Manufacturer: **Synatel Instrumentation Limited**  
Walsall Road  
Norton Canes  
Cannock  
Staffordshire  
WS11 9TB  
**United Kingdom**

Additional Manufacturing location  
(s):

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended.

#### STANDARDS:

The electrical apparatus and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards:

**IEC 60079-0 : 2011** Explosive atmospheres - Part 0: General requirements  
Edition: 6.0

**IEC 60079-18 : 2009** Explosive atmospheres Part 18: Equipment protection by encapsulation "m"  
Edition: 3

*This Certificate **does not** indicate compliance with electrical safety and performance requirements other than those expressly included in the Standards listed above.*

#### TEST & ASSESSMENT REPORTS:

*A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in*

Test Report:

[GB/BAS/ExTR12.0278/00](#)

Quality Assessment Report:

[GB/BAS/QAR06.0065/05](#)



# IECEx Certificate of Conformity

Certificate No.: IECEx BAS 12.0118X

Date of Issue: 2014-01-21

Issue No.: 0

Page 3 of 3

## Schedule

### EQUIPMENT:

*Equipment and systems covered by this certificate are as follows:*

The 30mm Range of Sensors consist of:

CxxxTxxAI Series of 30mm capacitance proximity switches.  
lxxxTxxAI Series of 30mm inductive proximity switches.  
PUxxTxxAI Series of 30mm speedswitches

Alternative Type Designation for Braime:

BSxxxxAI Series of 30mm capacitance proximity switches.  
P300xxxAI Series of 30mm inductive proximity switches  
M300xxxAI Series of 30mm speedswitches

The 30mm Range of Sensors are self-contained sensors with a variety of different functions and circuit options contained within a 30mm diameter x 93mm long black plastic moulded enclosure. The enclosure is encapsulated using epoxy resin. The product type is identified in the series and code on the label. The outer surface of the tubular enclosure is threaded M30 x 1.5mm for a length of 70mm starting at the sensor end of the enclosure. Two plastic nuts are supplied to clamp the sensor in a suitable mounting bracket, or the sensor can be clamped direct to a surface by suitable clips. An integral 2 wire cable is provided for connection to a 24-240V DC or 24-240V AC supply. The sensors may act as a switch with a maximum switching capacity of 100mA in which case they must be connected in series with a suitable load with the same voltage rating as the supply being used, which typically would be a relay.

Alternatively the sensor may be a 10-30V DC, 1W, 4 wire DC version which contains an output with a switching capacity of 30V DC at 100mA.

Alternatively the sensor may be a 15-240V DC or 24-240V AC 2VA, 5 wire universal version which contains an output with a switching relay capacity of 60V AC/DC, 3A (non inductive).

Alternatively the sensor may be a 12-240V DC or 24-240V AC 1VA, 4 wire universal version which contains an isolated, AC/DC opto-isolator with a switching capacity of 50mA.

The maximum power supplied to the sensor circuit is controlled by a 63mA fuse and two parallel zener diodes rated at 12V. The normal operating voltage is 6.2V for the 2 wire universal circuit, 10V for the 4 wire DC circuit and 8V for the 4 wire circuit. The input supply is protected by a thermal fuse rated at 98°C. The maximum power supplied to the 5 wire universal sensor circuit is controlled by a 50mA fuse with a normal operating voltage of 12V.

The 30mm Sensors have an Ingress Protection Rating equivalent to at least IP66.

### CONDITIONS OF CERTIFICATION: YES as shown below:

1. The supply circuit shall be protected by a suitably rated fuse capable of interrupting a short circuit current of 1500 Amps.
2. The external connections shall meet the requirements for EPL Ga in accordance with EN 60079-26 and EPL Da in accordance with EN 60079-31.
3. Warning: Potential static ignition risk, clean only with a damp cloth.
4. The integral cable shall be terminated in a suitably certified enclosure or in the safe area.

