

## AlarmSwitch

TECHNOLOGY . INNOVATION . QUALITY . VALUE

### **AlarmSwitch**

### **Alarm Monitoring System**

**X4004V4CAI** - A400 Elite Control Module – 12 - 24 DC Ex II 2D T125°C zones 21 & 22

**X4004V46CAI** - A400 Elite Control Module-95-250VAC /12-24DC Ex II 3D T125°C zone 22

#### **APPLICATION**

Unique low cost alarm/indicator panel for use with level indicators, hazard controls and limit switch devices.

#### METHOD OF OPERATION

The X400 ELITE is a microprocessor controlled unit which is able to accept signals from different sources in 8 zones, and is able to cause alarm and shutdown of the machine when alarm conditions are detected. The control unit is housed in a self contained wall mounting enclosure. A test push button on the lid of the control unit provides for full system verification. Alarm and status LEDs provide quick location of the alarm condition, and voltage free relay contacts provide separate alarm and shutdown control. An alarm mute push button is provided on the lid of the control unit and additional connections are provided for an external alarm mute push button.

#### **FEATURES**

- ▶ Monitors up to 8 Zones
- ▶ Multiple Alarm Inputs from Different Sensors
- ▶ LED Alarm Indication and Power Status
- ▶ Alarm Mute Automatic Reactivation on New Alarm
- ▶ Test Feature Externally Controlled Test Facility
- Dust Hazard Approved

#### Option

▶ TX400PLCB PLC Relay Board









ATEX zone 21 & 22

Detailed specification, wiring diagrams and installation/operating instructions available immediately upon request.

Please refer to instruction manual for correct installation. Information subject to change or correction. May 2007.



# Alarmswitch

TECHNOLOGY . INNOVATION . QUALITY . VALUE



#### **TECHNICAL SPECIFICATIONS**

AlarmSwitch - Alarm Monitoring System

V46CAI Imb -15°C to +50°C TEX0674X		
TEX0674X		
12 - 24 VDC		
12 - 24 V DG		
ct NO 8A 250VAC		
STOP A :1 contact NO 8A 250VAC		
I NO OA 250V AC		
HxLxP:246x188x102mm		

tease refer to instruction manual for correct installation. Information subject to change or correction. May 2007.